



Karnataka Fire and Emergency Services Department

Office of the District fire officer,

Peenya Fire Station

Peenya, Bengaluru-560058

Ph No 080 – 22971533



No: 42 /CC/DFO/PFS/2022

Date: 08-12-2022

To,

*The Authorized Signatory,  
M/s. Sri Balaji Educational Charitable Trust,  
Rainbow International School,  
No:08, Kereguddadahalli, Chikkabanavara main road,  
Bangalore-560090.*

Sir,

Sub : Issue of "**compliance report**" with respect to fire prevention, fire fighting and evacuation measures complied and maintained at *M/s. Sri Balaji Educational Charitable Trust, Rainbow International School, situated at No:08, Kereguddadahalli, Chikkabanavara main road, Bangalore-560090.*

Ref : 1. Our Department NOC No:42/FSR/DFO/PFS/2022, Dated:07-12-2022.  
2. Your letter dated: 06-12-2022.

\*\*\*\*\*

With reference to subject above cited, 'Fire Safety Recommendation' was issued wide reference (1) to the premises *M/s. Sri Balaji Educational Charitable Trust, Rainbow International School* situated at *No:08, Kereguddadahalli, Chikkabanavara main road, Bangalore-560090.* with a condition to fulfill the recommendations and compliance the same within 3 months.

With reference cited (2) above the above mentioned educational building was inspected on 06-12-2022 for issuing Compliance Certificate the management of *M/s. Sri Balaji Educational Charitable Trust, Rainbow International School* was complied the all recommendation communicated in Fire Safety Recommendation except training part.

Under the above circumstances the Karnataka Fire & Emergency Services Dept is issuing the '**Fire Safety Compliance Certificate**' to *M/s. Sri Balaji Educational Charitable Trust, Rainbow International School* situated at *No:08, Kereguddadahalli, Chikkabanavara main road, Bangalore-560090.* with an condition to attend the training part. Within 3 months and subject to proper maintenance of fire fighting systems.

**This Fire Safety Compliance Certificate is valid for only one year from the date of issue and it is renewable.**

Yours faithfully

  
District Fire Officer

Karnataka Fire & Emergency Services  
Peenya Fire Station, Bangalore-560 058

No: 42 /FSR/DFO/PFS/2022.

To,

**M/s. Sri Balaji Educational Charitable Trust**

Rainbow International School,  
No:08, Kereguddadahalli,  
Chikkabanavara Main road,  
Bangalore-560090.

Sir,

**Sub: Issue of 'Fire safety recommendation' to M/s. Sri Balaji Educational Charitable Trust, Rainbow International School Situated at No:08, Kereguddadahalli, Chikkabanavara Main road, Bangalore-560090.**

Ref: C.No:17/FSR/PFS/2022 Dt:- 06-12-2022.

\*\*\*\*\*

**ANNEXURE-B**

*NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.*  
**(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory)**

With reference to the subject above cited, 'Fire Safety Recommendation' was issued wide reference to the premises **M/s. Sri Balaji Educational Charitable Trust, Rainbow International School** Situated at **No:08, Kereguddadahalli, Chikkabanavara Main road, Bangalore-560090** was inspected by Fire Station Officer, Peenya Fire station on 06-12-2022 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

**A. Details of the building / premises :-**

01	Name and Address of the Applicant.	: <b><u>The Authorized Signatory,</u></b> <b><u>M/s. Sri Balaji Educational Charitable Trust</u></b> <b><u>Rainbow international School</u></b> No:08, Kereguddadahalli, Chikkabanavara main road, Bangalore-560090
----	------------------------------------	--

02	Name and Address of the premises.	:	<u>M/s. Sri Balaji Educational Charitable Trust,</u> <u>Rainbow international School</u> No:08, Kereguddadahalli, Chikkabanavara main road, Bangalore-560090
03	Name and address of the Building owner	:	<u>Secretary,</u> <u>M/s. Sri Balaji Educational Charitable Trust,</u> <u>Rainbow international School</u> No:08, Kereguddadahalli, Chikkabanavara main road, Bangalore-560090.
04	Number of buildings	:	One building Only.
05	Number of floors	:	Ground & 03 upper floors.
06	<u>Floor-wise details of occupancy:-</u>		
	Ground floor	:	Reception, 10 Class rooms & Toilet
	1 <sup>st</sup> floor	:	12 Class rooms & Toilet.
	2 <sup>nd</sup> floor	:	12 Class rooms & 01 Computer Lab, 01 Physics Lab, 01 chemistry Lab & Toilet
	3 <sup>rd</sup> floor	:	12 Class rooms, 01 botany Lab, 01 zoology Lab & Toilet.
07	Height of the building	:	13.71 Mtrs.
08	Site area	:	04 acres
09.	<u>Built-up area of each floor:-</u>		
	Ground floor	:	1162.63 Sq.mtrs.
	1 <sup>st</sup> floor	:	1162.63 Sq.mtrs.
	2 <sup>nd</sup> floor	:	1185.30 Sq.mtrs.
	3 <sup>rd</sup> floor	:	1185.30 Sq.mtrs
10.	<b>Total built-up area</b>	:	<b>4695.86 Sq.mtrs.</b>
11.	<u>Surrounding properties:-</u>		
	North (Front)	:	06.00 Mtrs wide Lakshmipura cross road
	South (Rear)	:	Open Land.
	East (Side)	:	Open Land
	West (Side)	:	Private Property

Set-back area available around the building :-

North (Front)	:	Min 06.00 Mtrs
South (Rear)	:	Min 06.00 Mtrs
East (Side)	:	Min 06.00 Mtrs
West (Side)	:	Min 06.00 Mtrs

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the Premises	The site is accessible from 09.00 mtrs wide kereguddadahalli cross road located on Northern side.	Adequate.
02.	No. of entrances	01 Entrance.	Complied.
03.	Width of entry / exit	One entrance of 06.00 mtrs wide on southern side.	Adequate.
04.	Diesel generators.	<b>Provided.</b> One generator of 125 Kva capacity available to supply alternative power for staircase lighting, corridor lighting and lifts, etc.. in the building.	<b>Complied.</b>
05.	No. of staircases available	Nos. of staircases : 02 No. Width of staircases : 01.30 Width of treads : 30 cms Height of risers : 15 cms Nos. of riser per flight : 10 No's Height of handrails : 01.00 M Head room clearance : 02.50 M	Adequate.
06.	No. of Lift & Capacity	No. of Lifts : 01 Capacity of lifts : 08 persons	

07.	Portable Fire extinguisher	<b>Provided.</b> 20 No's of ABC type fire extinguishers, One mechanical foam extinguisher of 09 ltrs capacity, One water mist extinguisher of 09 ltrs capacity & One CO2 type fire extinguisher, of 4.5 kgs capacity have been provided for all 03 floors of the building.	Complied.
08.	First aid Hose reel hose.	<b>Provided.</b> 04 No's of Hose reel hose have been provided near each Staircase. (One Hose reel hose system for every 1000 Sq. mtrs) the hose reel hose of minimum 19 mm size and of 30.00 mtrs length to reach the farthest point of each floor have been provide with a shut off branch having a nozzle of 5 mm size. The hose reel hose have been connected at each landing by means of an adaptor.	Complied.
09.	Terrace tank over respective tower terrace.	<b>Provided.</b> The system has been connected to an over head tank of 10.000 liters capacity & The water has been kept exclusively for fire fighting.	Complied.
10.	At the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup> .	<b>Provided.</b> The system has been connected to a Booster pump capable of delivering 450 LPM.	Complied.
11.	Escape routes	<b>Provided.</b> Directions in which the Teachers/Staff/Students have to move in the event of any emergency have been displayed in the corridor on each floor during evacuation.	Complied.

		<b>Provided.</b> Fire safety indicating the details of actions to be taken in case of emergency shall be displayed near each staircase landings with the telephone numbers of our Peenya Fire Station 080-22971545 & Central Fire Control Room No's 080-22971500/550/600 & 101 numbers & telephone numbers of nearest Ambulance Service.	<b>Complied.</b>
13.	No smoking board.	<b>Provided.</b> COPTA Sec-4, direction "No Smoking area smoking here is an offence" board written in English & Kannada both languages has been displayed at inside the entry/exit of each floor.	<b>Complied.</b>
14.	Fire Siren	<b>Provided.</b> A fire Siren has been installed in the premises to inform the inmates in case of fire emergency & evacuate the area.	<b>Complied.</b>
15.	Nominate one Fire Nodal Officer	<b>Provided.</b> The school authority has been nominated Mrs. Sanvika as a fire nodal officer.	<b>Complied.</b>
16.	Fire fighting training	Not provided.	Not complied At least 40% of employees shall be trained in basic fire fighting course at our R.A.Mundkur Fire and Emergency Services Training Academy, Bannerghatta Road, Bangalore-29 at an early Date or within 03 Months.

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing 'Fire Safety Recommendation' to M/s. Sri Balaji Educational Charitable trust ®, Rainbow International School situated at No:08, Kereguddadahalli, Chikkabanavara main road, Bangalore-560090 subject to condition and compliance of the above recommendations.

This 'Fire Safety Recommendation' is issued for a period of only one year from the date of issue.

♣ All requirements recommended above are as per National Building Code- 2016.

Yours faithfully



District Fire Officer  
Karnataka Fire & Emergency Services  
Peenya Fire Station, Bengaluru-560 058